



CABINET INTERCONNECTIONS

QTY	SYM	TYPE	NOTES
2	A	BUSS BAR	SUPPLIED
4	B	4/0 X-FLEX, 2 PER PHASE & GROUND #10, 1 PER NEUTRAL	SUPPLIED
2	C	24-12 AWG (2 EA, TWISTED PAIRS); CAT5, 4 PAIR UTP-24 AWG (3 EACH) 9-WIRE SERIAL CABLE; PHONE CABLE	SUPPLIED
1	D	CATS, 4 PAIR UTP-24 AWG (2 EACH)	SUPPLIED
1	E	CUSTOMER INTERFACE 24-12 AWG EPD-4 WIRES, INPUT CONTACTS-12 WIRES, OUTPUT CONTACTS-18 WIRES RJ45 6-PIN (MODERN) RJ45 8-PIN (NETWORK) DB9 (SERIAL)	(OPTIONAL) CUSTOMER SUPPLIED
1	F	BUSS BAR (PHASES) AND 2 EACH 4/0 X-FLEX (NEUTRAL)	SUPPLIED
1	G	4/0 X-FLEX, 2 PER NEUTRAL	SUPPLIED

1E2B40 SUPPLIER REPRINT
 1E2733 DRAWING - AUTOCAD
 1E10011 INTRP & TUL

DATE: 11/11/01
 DES: TI MATHEWS
 CHK: GM WILLIAMS
 APPR: RF THORN

UNLESS OTHERWISE SPECIFIED
 DIMENSIONS ARE IN INCHES
 DIMENSIONS IN MILLIMETERS ARE BASED ON:
 NONE

SCALE: NONE
 SHEET 1 OF 1 THIS DRAWING CHG DATE

CATERPILLAR INC.
 THE INFORMATION HEREIN IS THE PROPERTY OF CATERPILLAR INC. AND IS TO BE USED ONLY FOR THE SPECIFIC PROJECT AND NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM.

HYDRA-MON CONNECTION
 (UPS 600X4 WIRE)
 209-6780

LEVEL: CONTROL
 DATE: 11/11/01